



**Shivajirao Kadam Institute of Technology
& Management, Tillore Khurd,
Indore (M.P.)
Academic Year 2021-22**



ENERGY AUDIT CONSULTATION REPORT



SHIVAJIRAO KADAM INSTITUTE OF TECHNOLOGY & MANAGEMENT

**Near Ralamandal Sanctuary,
Tillore Khurd, Indore
(M.P.)**

PREPARED BY

EMPIRICAL EXERGY PRIVATE LIMITED
Flat No. 201, OM Apartment, 214 Indrapuri Colony,
Bhawarkuan, Indore – 452 001 (M. P.), India
0731-4948831, 7869327256
Email ID: eempirical18@gmail.com
www.eeplgroups.com
(Academic Year 2021-22)



CONTENT

| Sr. No. | Items | Page No. |
|-------------------|---------------------------------------------------------------------------------------------|----------|
| I | ACKNOWLEDGEMENT | 3 |
| II | Certificate Of Accreditation | 4 |
| III | Green Monitoring Committee | 5 |
| IV | Audit Team | 6 |
| V | Executive Summary | 7 |
| Chapter-1 | Introduction | 9 |
| 1.1 | About Institute | 9 |
| 1.2 | About Energy Audit | 11 |
| 1.3 | Objectives of Energy Audit | 11 |
| 1.4 | Methodology | 12 |
| 1.5 | Present Energy Scenario of Institute | 12 |
| Chapter- 2 | Power Supply System | 14 |
| 2.1 | Power Supply System | 14 |
| 2.2 | Loading of Transformer | 14 |
| 2.3 | DG Set | 15 |
| Chapter- 3 | Electricity Bill Analysis Year 2021-22 | 16 |
| 3.1 | Monthly Electrical Energy Consumption | 16 |
| 3.2 | Monthly Demand Analysis | 17 |
| 3.3 | Monthly Power Factor Analysis | 18 |
| 3.4 | Monthly Peak and off. Peak period unit consumption analysis | 19 |
| 3.5 | Monthly Average Load Factor analysis | 20 |
| 3.6 | Connected Load details of institute | 21 |
| 3.7 | Connected Load Sharing Electrical Equipment's | 26 |
| 3.8 | Some Photograph of Electrical Equipment's | 27 |
| Chapter- 4 | Energy Conservation and Recommendation | 28 |
| Case Study-4.1 | Replacement of conventional (tube light) 54 Watt by energy efficient 20 Watt LED tube light | 28 |
| Case Study-4.2 | Replacement of 60 Watt conventional ceiling fan by 28Watt BLDC Energy efficient ceiling fan | 29 |
| Case Study-4.3 | Installation 52.80 kWp grid connected solar roof top system | 30 |



**Shivajirao Kadam Institute of Technology
& Management, Tillore Khurd,
Indore (M.P.)
Academic Year 2021-22**



ACKNOWLEDGEMENT

Empirical Exergy Private Limited (EEPL), Indore takes this opportunity to appreciate & thank the management of “**Shivajirao Kadam Institute of Technology & Management**” Ralamandal Sanctuary, Tillore Khurd, Indore (M.P.) for giving us an opportunity to conduct energy audit for the institute.

We are indeed touched by the helpful attitude and co-operation of all faculties and technical staff, who rendered their valuable assistance and co-operation the course of study.




Rajesh Kumar Singadiya
(Director)


M.Tech (Energy Management), PhD (Research Scholar)
Accredited Energy Auditor [AEA-0284]
Certified Energy Auditor [CEA-7271]
(BEE, Ministry of Power, Govt. of India)
Empanelled Energy Auditor with MPUVN, Bhopal M.P.
Lead Auditor ISO50001:2011 [EnMS) from FICCI, Delhi
Certified Water Auditor (NPC, Govt of India)
Chartered Engineer [M-1699118], The Institution of Engineers (India)
Member of ISHRAE [58150]



Certificate of Accreditation

 **BUREAU OF ENERGY EFFICIENCY**

Examination Registration No.: **EA-7271**
Accreditation Registration No.: **AEA-284**



Certificate of Accreditation

This is to certify that Mr./Ms. **Shri. Rajesh Kumar Singadiya** having its trade/registered office at has been given accreditation as accredited energy auditor. The certificate shall be effective from **9th** day of **May, 2018**.


The certificate is subject to the provisions of the Bureau of Energy Efficiency (Qualifications for Accredited Energy Auditors and Maintenance of their List) Regulations, 2010.

This certificate shall be valid until it is cancelled under regulation 9 of the Bureau of Energy Efficiency (Qualifications for Accredited Energy Auditors and Maintenance of their List) Regulations, 2010.

On cancellation, the certificate of accreditation shall be surrendered to the Bureau within fifteen days from the date of receipt of order of cancellation.

Your name has been entered at AEA No. **284** in the register of list of accredited energy auditors. Your name shall be liable to be struck out on the grounds specified in regulation 8 of the Bureau of Energy Efficiency (Qualifications for Accredited Energy Auditors and Maintenance of their List) Regulations, 2010.

Given under the seal of the Bureau of Energy Efficiency, Ministry of Power, this **5th** day of **October, 2018**


Secretary,
Bureau of Energy Efficiency
New Delhi



Green Monitoring Committee

Transnational Knowledge Society's
Shivajirao Kadam Institute of Technology and Management
Skill. Innovation. Transformation
(Approved by AICTE, New Delhi. Affiliated to RGPV, Bhopal and DAVV, Indore. Recognized by DTE, Bhopal, Govt. of Madhya Pradesh)
An ISO 9001:2015 Certified Institute

SKITM/PRI./2021-22/08 DATE 23/08/2021

Green Monitoring Committee

| S. No. | Name of Members | Designation | Mobile No. | Email-id |
|--------|----------------------|----------------------|------------|-----------------------|
| 1 | Dr. Sanjay T. Purkar | Director | 9301223688 | sanjaypurkar@skitm.in |
| 2 | AVM Praveen Kumar | Dean Student Affairs | 9424008366 | praveenkumar@skitm.in |

Dr. Sanjay T. Purkar
Director

Director
Shivajirao Kadam Inst. of Tech
& MGMT- Technical Campus
INDORE (M.P.)



Audit Team

The study team constituted of the following senior technical executives from **Empirical Exergy Private Limited,**

- ✚ **Mr. Rakesh Pathak,** [Director & Electrical Expert]
- ✚ **Mr. Rajesh Kumar Singadiya** [Director & Accredited Energy Auditor AEA-0284]
- ✚ **Mrs. Laxmi Raikwar Singadiya** [Energy & Chemical Engineer]
- ✚ **Mr. Sachin Kumawat** [Sr. Project Engineer]
- ✚ **Mr. Ajay Nahra** [Engineer]
- ✚ **Mr. Charchit Pathak** [Mechanical Engineer]
- ✚ **Mr. Aakash Kumawat** [Assistant Jr. Engineer]



EXECUTIVE SUMMARY

The executive summary of the energy audit report furnished in this section briefly gives the identified energy conservation measures and other recommendation during the project that can be implemented in a phased manner to conserve energy, increase productivity inside the institute campus.

RECOMMENDATION: -

+ SOLAR SYSTEM

There is good potential to install 52.80 kWp roof top grid connected solar system. Expected annual solar energy generation @ 4 unit per kilowatt is 7708 units.

+ LIGHTING SYSTEM

Institute has already initiated installation of energy efficient lighting in building and replacement of “conventional tube light by energy efficient LED tube light. Still there are good potential for replacement of 429 no. of conventional T-12 (54Watt)” tube light by energy efficient 20Watt LED lighting in institute estimated energy saving potential is 29,172 kWh/Year.

+ Ceiling Fan AND Exhaust Fan

Replacement of “conventional ceiling fan (75 Watt)” by energy efficient star rated fan or BLDC based energy efficient fan (28 Watt) in class rooms, laboratories and faculties cabin” have great potential for energy saving.

+ TIMER CONTROLLED STREET LIGHTS

Installation of “Timer control on street lighting” in institute campus is recommended.

+ ENERGY MANAGEMENT WORKSHOP AND TRAINING

Conduct awareness, training programs, seminars, workshops, exhibitions for faculty, management and nonteaching staff.



ENERGY CONSERVATION MEASURES FOR ELECTRICAL SYSTEM

| Case Study | Section | Identification | Observation | Recommendation | Annual Energy Saving (kWh) | Annual Cost Saving (Rs.) | Investment (Rs.) | Simple Payback Period |
|-------------------|-------------------|-----------------------------------|-----------------------------------------------------|------------------------------------------------------------|-----------------------------------|---------------------------------|-------------------------|------------------------------|
| 1 | Lighting System | 429 No. FTL tube light | Power consumption by T-12 FTL | Replacement of conventional (T-12) with (20 Watt LED Tube) | 29,172 | 2,78,417/- | 90,090/- | 4 month |
| 2 | Ceiling Fan | 31 No. Ceiling Fan | Power consumption by existing ceiling fan (75 Watt) | Replacement of 75W conventional ceiling fan by 28W BLDC | 33,216 | 3,17,014/- | 8,71,920/- | 2.8 Year |
| 3 | Electrical System | There is good potential for solar | 100 percent energy consumption from grid | Installation of 52.80 KWp solar system | 15,2445 | 7,70,880/- | 23,76,000 | 3.1 year |



CHAPTER-1 INTRODUCTION

1.1 About Institute

Shivajirao Kadam Institute of Technology and Management (SKITM) was founded in the year 2019, with its first intake as SKITM in 2020, after taking over the Erstwhile Acropolis Technical Campus. SKITM is under the aegis of Transnational Knowledge Society, which was founded in the year 2008. Under the visionary leadership of renowned academician Prof. Shivajirao Kadam, the institution aims to transform the lives of its students and establish itself as the center of excellence in the state of Madhya Pradesh. The institute works on three key principles – Skill, Innovate and Transform. Our unique methodology distinguishes us from the rest of the institutions. We are highly focused on practical aspects of education, we aim to make our students ready to take up the real world challenges which the industry poses at them. We currently have 4 schools which offer B.TECH (CSE, MECH, CIVIL, EC), B.COM, BBA, Integrated BBA-MBA, B.Pharm, MBA as well as Diploma in Mechanical, Civil and Pharmacy. With the unrivalled leadership and the guidance of our Mentors, SKITM is changing the design and nature of education. SKITM will be recognized for the impact its teachings will have on its students and the community at large. Our Extensive Training Sessions, Unique Teaching Methodology, Strong Collaborations, Impactful Certifications and Partnerships make us the up and coming institute in Central India.




Figure - 1.1 Satellite image of SKITS Institute (Source – Google)



**Shivajirao Kadam Institute of Technology &
Management Near Ralamandal Sanctuary,
Tillore Khurd, Indore (M.P.)
Academic Year 2021-22**



Vision

Holistic development of the learner through excellence in education, innovation & research.

Mission

1. To create competitive and technically empowered environment which enable students to develop and discover their potential and become competent to address industrial, societal and global challenges.
2. To achieve academic excellence in application-oriented research, novelty and creativity leading to emergence of technocrats, leaders, innovators and renowned entrepreneurs.
3. To become a top school in country where students are raised with Holistic learning for inculcating core values of professionalism, gender equality, transparency and ethics.
4. To establish partnership with globally recognized institutions and organizations to foster students with industrial exposure through extensive hands-on training.
5. To ensure overall nurturing and all-round personality development of students by continues monitoring and guidance.



1.2 About Energy Audit

Energy audit helps to understand more about the ways energy is used in any plant and helps in identifying areas where waste may occur and scope for improvement exists. The overall energy efficiency from generation to final consumer becomes 50%.

Energy audit is the most efficient way to identify the strength and weakness of energy management practices and to find a way to solve problems. Energy audit is a professional approach in utilizing economic, financial, and social and natural resources responsibility. Energy audits “adds value” to management control and is a way of evaluating the system.

Empirical Exergy Private Limited (EEPL), Indore M.P. carried out the “Energy Audit” at the site to find gaps in the energy consumption pattern for **Shivajirao Kadam Institute of Technology & Management** technical report is prepared as per the need and the requirement of the project.

1.3 Objectives of Energy Audit

An energy audit provides vital information base for overall energy conservation program covering essentially energy utilization analysis and evaluation of energy conservation measures. It aims at:

- Identifying the quality and cost of various energy inputs.
- Assessing present pattern of energy consumption in different cost centers of operations.
- Relating energy inputs and production output.
- Identifying potential areas of thermal and electrical energy economy.
- Highlighting wastage in major areas.
- Fixing of energy saving potential targets for individual cost centers.
- Implementation of measures for energy conservation & realization of savings.



1.4 Methodology

Methodology adopted for achieving the desired objectives viz.: Assessment of the current operational status and energy savings include the following:

- ✚ Discussions with the concerned officials for identification of major areas of focus and other related systems.
- ✚ Team of engineers visited the site and had discussions with the concerned officials / supervisors to collect data / information on the operations and load distribution within the plant and same for the overall premises. The data was analyzed to arrive at a base line energy consumption pattern.
- ✚ Measurements and monitoring with the help of appropriate instruments including continuous and / or time-lapse recording, as appropriate and visual observations were made to identify the energy usage pattern and losses in the system.
- ✚ Trend analysis of costs and consumptions.
- ✚ Capacity and efficiency test of major utility equipment's, wherever applicable.
- ✚ Estimation of various losses
- ✚ Computation and **in-depth analysis** of the collected data, including utilization of computerized analysis and other techniques as appropriate were done to draw inferences and to evolve suitable energy conservation plan/s for improvements/ reduction in specific energy consumption.

1.5 Present Energy Scenario

Institute uses energy in the form of electricity purchased from MPPKVCL grid. The institute has non industrial 33KV feeder with contract demand 100 KVA. As per applicable tariff HV-3.2.B non-industrial 33KV feeder fixed charges is Rs. 485/- per KVA and energy charges Rs. 7.38 per unit.


Total billing amount of Shivajirao Kadam Institute of Technology & Management of institute is INR 17,75,029/- with respect to annual energy consumption 1,52,445unit analysis period from Jul-2021 to Jun-2022. Annual average per unit charges paid by institute is Rs.11.93 per unit.



Shivajirao Kadam Institute of Technology & Management Near Ralamandal Sanctuary, Tillore Khurd, Indore (M.P.)
Academic Year 2021-22



Institute Layout





CHAPTER-02 POWER SUPPLY SYSTEM

2.1 Power Supply System

The power supply for the Shivajirao Kadam Institute of Technology & Management from MPPKVCL with the help of 33 kV feeder under tariff HV-3.2.B Non-Industrial. There is single transformer has capacity 200 KVA. Detail of the transformer is given in table 2.1

| Sr. No. | Items | Technical specification | Unit |
|---------|--------------------|-------------------------|------|
| 1 | Make | Sterling | |
| 2 | Year | 2010 | |
| 3 | Rating | 200 | KVA |
| 4 | Voltage (HV/LV) | 33000/433 | V |
| 5 | Current (HV/LV) | 3.5/266.67 | Amp |
| 6 | Frequency | 50 | Hz |
| 7 | Impedance | 4 | % |
| 8 | Vector Group | Dyn11 | |
| 9 | Type of cooling | ONAN | |
| 10 | Total no. of Tap | 5 | No. |
| 11 | Ideal Tap Position | 3 | |

2.2 Loading of transformer: The load of the transformer is calculated based on maximum demand appear in electricity bill.




Figure 2.3:- Graphical presentation of TR loading percentage Year 2021-22

Observation: - The average loading of the transformer is 30%. It is acceptable.



2.3 DG Set

There is DG set in institute campus. Detailed of the DG set are given table

Table 2.2 Technical specifications for DG set

| Sr. No. | Parameter | Technical specification | Units |
|---------|-------------------|-------------------------|-------|
| 1 | Make | Stanford | |
| 2 | M/C No | N156278738 | |
| 3 | Capacity | 160 | KVA |
| 4 | Rated Voltage | 415 | Volt |
| 5 | Full load current | 222.6 | Amp. |
| 6 | Frequency | 50 | Hz. |
| 7 | Power factor | 0.8 | |
| 8 | Speed | 1500 | RPM |
| 9 | Phase | 3 | |



Figure 2.4: - DG set in Institute

Observation :

- DG set is used only in case of grid power failure.
- There is no system to monitor fuel consumption w.r.t. unit generation.
- It is suggested to maintain logbook for unit generation and fuel consumption of DG set.



CHAPTER- 3 ELECTRICITY BILL ANALYSIS

3.1 Monthly Electrical Energy Consumption (Year 2021-22)

The monthly unit consumption given in table.

Table 3.1 Energy consumption and billing amount (the year 2021-22)

| Sr. No. | Month & Year | Unit consumption (kWh/Month) | Total Amount (Rs /Month) | Overall Unit Charges (Rs/kWh) |
|---------|--------------|------------------------------|--------------------------|-------------------------------|
| 1 | Jul-21 | 6,732 | 94,687/- | 14.07 |
| 2 | Aug-21 | 7,554 | 1,01,359/- | 13.42 |
| 3 | Sep-21 | 10,881 | 1,27,408/- | 11.71 |
| 4 | Oct-21 | 13,236 | 1,43,991/- | 10.88 |
| 5 | Nov-21 | 11,937 | 1,30,991/- | 10.97 |
| 6 | Dec-21 | 11,361 | 1,27,480/- | 11.22 |
| 7 | Jan-22 | 11,622 | 1,32,469/- | 11.40 |
| 8 | Feb-22 | 11,991 | 1,99,777/- | 16.66 |
| 9 | Mar-22 | 12,609 | 1,38,449/- | 10.98 |
| 10 | Apr-22 | 16,257 | 1,72,065/- | 10.58 |
| 11 | May-22 | 19,281 | 2,09,005/- | 10.84 |
| 12 | Jun-22 | 18,984 | 1,97,348/- | 10.40 |
| | Total | 1,52,445 | 17,75,029/- | 11.93 |




Figure 3.1: - Monthly Unit Consumption year-2021-22

Observation - Annual energy consumption is 1,52,445 units and overall per unit charges is Rs.11.93 per unit.



3.2 Monthly demand analysis (Year 2021-22).

The monthly demand consumption for the institute is given in the table.

Table 3.2: - Monthly demand analysis (KVA) consumption pattern year 2021-22

| Sr. No. | Month & Year | Contract Demand (kVA) | Maximum Demand (kVA) | Billing Demand (kVA) |
|---------|--------------|-----------------------|----------------------|----------------------|
| 1 | Jul-21 | 100 | 42 | 90 |
| 2 | Aug-21 | 100 | 40 | 90 |
| 3 | Sep-21 | 100 | 40 | 90 |
| 4 | Oct-21 | 100 | 65 | 90 |
| 5 | Nov-21 | 100 | 50 | 90 |
| 6 | Dec-21 | 100 | 44 | 90 |
| 7 | Jan-22 | 100 | 38 | 90 |
| 8 | Feb-22 | 100 | 43 | 90 |
| 9 | Mar-22 | 100 | 59 | 90 |
| 10 | Apr-22 | 100 | 87 | 90 |
| 11 | May-22 | 100 | 112 | 112 |
| 12 | Jun-22 | 100 | 99 | 99 |




Figure 3.2:- Graphical presentation of demand consumption year-2021-22

Observation – Maximum demand is always less than billing demand from July 2021 April 2022 in the month of May 2022 and Jun-2022 maximum demand is equal to billing demand due to cooling load of the institute



3.3 Monthly Power factor analysis (Year 2021-22)

The monthly power factor for the institute is given in the following table.

Table 3.3:- Power factor of the institute year 2021-22.

| Sr. No | Month & Year | Monthly Power Factor | Inventive Percentage (%) | Incentives Amount (Rs. / Month) |
|--------|--------------|----------------------|--------------------------|---------------------------------|
| 1 | Jul-21 | 0.952 | 1 | 475/- |
| 2 | Aug-21 | 0.954 | 1 | 533/- |
| 3 | Sep-21 | 0.956 | 1 | 767/- |
| 4 | Oct-21 | 0.986 | 5 | 4,752/- |
| 5 | Nov-21 | 0.985 | 5 | 4,552/- |
| 6 | Dec-21 | 0.989 | 5 | 4,079/- |
| 7 | Jan-22 | 0.988 | 5 | 4,254/- |
| 8 | Feb-22 | 0.986 | 5 | 4,389/- |
| 9 | Mar-22 | 0.984 | 5 | 4,615/- |
| 10 | Apr-22 | 0.988 | 5 | 5,997/- |
| 11 | May-22 | 0.989 | 5 | 7,173/- |
| 12 | Jun-22 | 0.990 | 5 | 7,062/- |
| | | | 4 | 48,645/- |




Figure 3.2: - Graphical presentation of demand consumption year-2021-22

Observation – Monthly Average Power Factor is 0.979 and Annual P.F. incentive is taken Rs.48,645/- It's appreciable.



3.4 Monthly Peak and off. Peak period unit consumption analysis year 2021-22

The monthly Peak period and Off. Peak Period consumption for the institute is given in the following table.

Table 3.4:- Peak Period and Off. Peak Period of the institute year 2021-22.

| Sr. No. | Month& Year | Total Unit | Peak Period Unit | Off. Peak Period | Normal Period Time |
|---------|-------------|------------|------------------|------------------|--------------------|
| 1 | Jul-21 | 1267 | 942 | 2436 | 6044 |
| 2 | Aug-21 | 1295 | 1263 | 2430 | 5623 |
| 3 | Sep-21 | 1392 | 1851 | 2649 | 5904 |
| 4 | Oct-21 | 1592 | 1944 | 2754 | 6148 |
| 5 | Nov-21 | 1725 | 1790 | 2877 | 5799 |
| 6 | Dec-21 | 1584 | 1857 | 2610 | 5337 |
| 7 | Jan-22 | 1524 | 1938 | 2406 | 5397 |
| 8 | Feb-22 | 1767 | 2049 | 2487 | 5829 |
| 9 | Mar-22 | 1677 | 1992 | 2469 | 6834 |
| 10 | Apr-22 | 1770 | 2010 | 2580 | 5328 |
| 11 | May-22 | 1656 | 2286 | 2454 | 3504 |
| 12 | Jun-22 | 1119 | 2196 | 1623 | 2442 |
| | Total | | | | |




Figure 3.1: - Time of the day unit consumption year-2021-22

Observation-The Average Peak Period Unit 14.5%, Off. Peak Period Unit 21%, Normal Period Unit 64.5% for the year 2021-22.



3.5 Monthly Average Load Factor analysis (Year 2021-22)

The monthly Avg. Load Factor for the institute is given in the following table.

Table 3.4:- Avg. Load Factor of the institute year 2021-22.

| Sr. No. | Month & Year | Avg. Load factor (%) |
|---------|--------------|----------------------|
| 1 | Jul-21 | 7.00 |
| 2 | Aug-21 | 9.00 |
| 3 | Sep-21 | 10.00 |
| 4 | Oct-21 | 15.00 |
| 5 | Nov-21 | 15.00 |
| 6 | Dec-21 | 15.00 |
| 7 | Jan-22 | 15.00 |
| 8 | Feb-22 | 16.00 |
| 9 | Mar-22 | 19.00 |
| 10 | Apr-22 | 22.00 |
| 11 | May-22 | 24.00 |
| 12 | Jun-22 | 25.00 |




Figure 3.1: - Monthly Avg. Load Factor year-2021-22

Observation - Annual Avg. Load Factor is 16%



3.6 Connected Load details of institute

| M.E. Department | | | | | |
|-----------------|-------------------------|-----|------------|----|-----|
| Sr. No. | Location | Fan | Tube light | PC | CFL |
| 1 | 118E lab M.D. | 5 | 5 | 1 | 0 |
| 2 | 117A Thermal lab | 4 | 6 | 0 | 0 |
| 3 | 117B TOM DOM lab | 5 | 7 | 1 | 0 |
| 4 | 118A Metopology lab | 3 | 3 | 0 | 0 |
| 5 | 118B FM lab | 5 | 4 | 1 | 0 |
| 6 | 118C H.M.T(Vibious) | 5 | 5 | 2 | 0 |
| 7 | 118D RAC lab | 5 | 5 | 2 | 0 |
| 8 | 106A M.M.C lab | 4 | 7 | 4 | 0 |
| 9 | 107A CAD lab | 7 | 4 | 26 | 0 |
| 10 | 108 Class Room | 6 | 4 | 0 | 0 |
| 11 | 109 Class Room | 6 | 4 | 0 | 0 |
| 12 | 116C Class Room | 4 | 4 | 0 | 0 |
| 13 | 112B HOD Room | 1 | 1 | 1 | 0 |
| 14 | 112D | 1 | 1 | 0 | 0 |
| 15 | Toilet | 0 | 1 | 0 | 0 |
| 15 | 112C Office ME. | 1 | 1 | 3 | 0 |
| 6 | 115 Class Room | 6 | 6 | 0 | 0 |
| 17 | Workshop 005 | 12 | 4 | 0 | 7 |
| 18 | 005A.B.ICE Auto machine | 5 | 8 | 0 | 0 |
| 19 | Outside Room | 4 | 16 | 0 | 0 |
| | | 85 | 76 | 41 | 7 |



| E.C.E Department | | | | | | | |
|-------------------------|-----------------|------------|-------------------|-----------|----------------|---------------|------------|
| Sr. No. | Location | Fan | Tube light | PC | Printer | Cooler | LED |
| 1 | Room No. 202 | 5 | 6 | 4 | 0 | 0 | 0 |
| 2 | Room No. 201 | 6 | 4 | 0 | 0 | 0 | 0 |
| 3 | Room No. 203 | 4 | 2 | 0 | 0 | 0 | 0 |
| 4 | Room No.105A | 7 | 5 | 10 | 0 | 0 | 0 |
| 5 | Room No.105C | 4 | 4 | 0 | 0 | 0 | 0 |
| 6 | Room No.105D | 4 | 4 | 5 | 0 | 0 | 0 |
| 7 | Room No.105E | 7 | 7 | 0 | 0 | 0 | 0 |
| 8 | Room No.105F | 6 | 6 | 8 | 0 | 0 | 0 |
| 9 | Room No.104 | 2 | 2 | 0 | 2 | 3 | 0 |
| 10 | Ground floor | 5 | 27 | 0 | 0 | 0 | 0 |
| 11 | Ground floor | 0 | 0 | 0 | 0 | 0 | 6 |
| 12 | Ground floor | 0 | 0 | 0 | 0 | 0 | 8 |



| C.S.E Department | | | | | |
|------------------|---------------------------|-----|------------|----|------|
| Sr. No. | Location | Fan | Tube light | PC | A.C. |
| 1 | Lab 205A | 7 | 5 | 8 | 0 |
| 2 | Lab 205B | 7 | 5 | 30 | 0 |
| 3 | Lab. N | 2 | 2 | 8 | 0 |
| 4 | C.O | 12 | 8 | 60 | 0 |
| 5 | 205E | 7 | 4 | 30 | 0 |
| 6 | 205A | 7 | 4 | 30 | 0 |
| 7 | 206B | 9 | 6 | 60 | 0 |
| 8 | RAG | 2 | 2 | 6 | 0 |
| 9 | 222 | 6 | 6 | 0 | 0 |
| 10 | 221 | 4 | 4 | 0 | 0 |
| 11 | 217A | 3 | 3 | 0 | 0 |
| 12 | 206D | 2 | 2 | 8 | 0 |
| 13 | Toilet | 0 | 1 | 0 | 0 |
| 14 | Excon Room | 4 | 4 | 3 | 0 |
| 15 | 214 | 4 | 4 | 0 | 0 |
| 16 | 207A | 3 | 2 | 2 | 1 |
| 17 | 207B | 6 | 4 | 0 | 0 |
| 18 | 20A | 4 | 4 | 0 | 0 |
| 19 | 20B | 4 | 4 | 0 | 0 |
| 20 | 216 | 4 | 4 | 0 | 0 |
| 21 | 215 | 6 | 6 | 60 | 0 |
| 22 | 208 | 4 | 4 | 0 | 0 |
| 23 | 209 | 4 | 4 | 0 | 0 |
| 24 | 210 | 4 | 4 | 0 | 0 |
| 25 | 211 | 4 | 4 | 0 | 0 |
| 26 | cabin | 24 | 24 | 0 | 0 |
| 27 | C.S Office | 1 | 2 | 0 | 0 |
| 28 | C.S HOD | 1 | 1 | 0 | 1 |
| 29 | HOD | 1 | 1 | 0 | 0 |
| 30 | HOD | 1 | 1 | 0 | 0 |
| 31 | HOD | 5 | 5 | 0 | 0 |
| 32 | Second floor Outside room | 0 | 6 | 0 | 0 |
| 33 | Third floor | 0 | 7 | 0 | 0 |



| Pharmacy Building | | | | | | | |
|-------------------|------------------------|-----|------------|----|---------|------|-----------|
| Sr. No. | Location | Fan | Tube light | PC | Printer | A.C. | Projector |
| 1 | Class Room 1 | 9 | 12 | 0 | 0 | 0 | 1 |
| 2 | Class Room 2 | 9 | 11 | 0 | 0 | 0 | 0 |
| 3 | Class Room 3 | 9 | 12 | 0 | 0 | 0 | 0 |
| 4 | Class Room 5 | 4 | 7 | 0 | 0 | 0 | 0 |
| 5 | Principle Office | 4 | 4 | 1 | 1 | 1 | 0 |
| 6 | Computer lab | 6 | 7 | 22 | 0 | 1 | 0 |
| 7 | Machine Room II | 5 | 8 | 0 | 0 | 0 | 0 |
| 8 | Office | 3 | 4 | 2 | 0 | 0 | 0 |
| 9 | Faculty Room II | 5 | 7 | 5 | 0 | 0 | 0 |
| 10 | Faculty Room I | 5 | 5 | 3 | 0 | 0 | 0 |
| 11 | Machine Room I | 5 | 8 | 0 | 0 | 0 | 0 |
| 12 | Central Stair | 0 | 0 | 0 | 0 | 0 | 0 |
| 13 | Pharmaceutical Lab III | 6 | 2 | 0 | 0 | 0 | 0 |
| 14 | Analysis Lab | 6 | 5 | 0 | 0 | 0 | 0 |
| 15 | Instrument Room | 4 | 12 | 2 | 0 | 1 | 0 |
| 16 | Pharmacognosy Lab II | 6 | 2 | 0 | 0 | 0 | 0 |
| 17 | Microbiology Lab | 5 | 4 | 0 | 0 | 0 | 0 |
| 18 | Pharmacognosy Lab I | 5 | 4 | 0 | 0 | 0 | 0 |
| 19 | HAP Lab | 5 | 8 | 0 | 0 | 0 | 0 |
| 20 | Chemistry lab III | 3 | 6 | 0 | 0 | 0 | 0 |
| 21 | Class Room VI | 0 | 8 | 0 | 0 | 0 | 0 |
| 22 | Chemistry Lab I | 7 | 5 | 0 | 0 | 0 | 0 |
| 23 | Chemistry Lab II | 3 | 6 | 0 | 0 | 0 | 0 |
| 24 | Ceutics Lab I | 4 | 5 | 0 | 0 | 0 | 0 |
| 25 | Ceutics Lab I | 7 | 6 | 0 | 0 | 0 | 0 |
| 26 | Ream | 2 | 2 | 0 | 1 | 0 | 0 |
| 27 | GCR | 0 | 1 | 1 | 0 | 0 | 0 |
| 28 | Class Room IV | 9 | 11 | 0 | 0 | 0 | 0 |
| 29 | Cognecy | 4 | 5 | 0 | 0 | 0 | 0 |
| 30 | Exam | 0 | 0 | 0 | 1 | 0 | 0 |
| 31 | Exam | 2 | 2 | 1 | 1 | 0 | 0 |
| 32 | GCR | 0 | 1 | 0 | 0 | 0 | 0 |
| 33 | Class Room IV | 0 | 0 | 0 | 0 | 0 | 0 |
| 34 | Cognosy III | 0 | 0 | 0 | 0 | 0 | 0 |
| 35 | Washroom | 0 | 3 | 0 | 0 | 1 | 0 |
| 36 | Lobby Area | 1 | 20 | 0 | 0 | 0 | 0 |



| MBA | | | | | | |
|---------|----------------------------|-----|---------------------------------|----|----|-----------------|
| Sr. No. | Location/RoomNo. | Fan | Tube light/ Ceiling Light | PC | AC | Street light |
| 1 | 012B | 1 | 1 | 1 | 0 | 0 |
| 2 | 012C | 2 | 3 | 5 | 0 | 0 |
| 3 | 015 | 6 | 15 | 0 | 2 | 0 |
| 4 | 011 Class Room | 5 | 4 | 0 | 0 | 0 |
| 5 | 010 Class Room | 6 | 4 | 0 | 0 | 0 |
| 6 | 111 Class Room | 6 | 4 | 0 | 0 | 0 |
| 7 | 110 Class Room | 6 | 4 | 0 | 0 | 0 |
| 8 | 115A | 4 | 4 | 5 | 0 | 0 |
| 9 | 012A Director Sir | 1 | 1 | 1 | 1 | 0 |
| 10 | Outside institute building | 0 | 0 | 0 | 0 | 20 |

| Civil Department | | | | | | |
|------------------|------------------|-----|------------|----|---------|----------|
| Sr. No. | Location/RoomNo. | Fan | Tube light | PC | Printer | Wall fan |
| 1 | 014 B (Office) | 2 | 5 | 2 | 2 | 0 |
| 2 | 017A Lab | 10 | 8 | 1 | 0 | 0 |
| 3 | 016 A | 8 | 14 | 1 | 0 | 0 |
| 4 | 016B | 7 | 13 | 2 | 0 | 0 |
| 5 | 017 B | 3 | 4 | 0 | 0 | 0 |
| 6 | 018 A | 5 | 3 | 2 | 0 | 0 |
| 7 | 018 B | 5 | 5 | 1 | 0 | 0 |
| 8 | 116 A | 5 | 4 | 0 | 0 | 0 |
| 9 | 116 B | 3 | 4 | 0 | 0 | 0 |
| 10 | Reception | 0 | 0 | 0 | 0 | 1 |

| Canteen | |
|---------|------------|
| Fan | Tube light |
| 19 | 19 |



3.7 Connected Load sharing Electrical Equipment

Table-3.7 Total load share of electrical equipment in institute.

| Sr. No. | Equipment's | Unit Power (watt) | Quantity | Total Power (Watt) | Load share% |
|---------|----------------------------|-------------------|----------|--------------------|-------------|
| 1 | Tube light | 54 | 429 | 23166 | 17.70 |
| 2 | LED Tube (20 watt) | 20 | 6 | 120 | 0.09 |
| 3 | Ceiling fan | 60 | 519 | 31140 | 26.70 |
| 4 | Computer | 75 | 431 | 32325 | 24.70 |
| 5 | Printer | 320 | 8 | 2560 | 1.96 |
| 6 | Split A.C. | 1450 | 9 | 13050 | 9.97 |
| 7 | Wall Fan | 60 | 1 | 60 | 0.05 |
| 8 | Street light Metal Halide | 400 | 3 | 1200 | 0.92 |
| 9 | Street light LED | 200 | 7 | 1400 | 1.07 |
| 10 | Lift | 4000 | 1 | 4000 | 3.06 |
| 11 | Air Cooler | 150 | 3 | 450 | 0.34 |
| 12 | CFL | 15 | 7 | 105 | 0.08 |
| 13 | Ceiling light LED | 12 | 8 | 96 | 0.07 |
| 14 | Bore -1 behind Engg. Block | 3730 | 1 | 3730 | 2.85 |
| 15 | Bore-2 Near Pharmacy block | 3730 | 1 | 3730 | 2.85 |
| 16 | Bore -3 Near CPS Block | 3730 | 1 | 3730 | 2.85 |
| 17 | Bore-4 Near Garden | 2238 | 1 | 2238 | 1.71 |
| Total | | | | 130885 | 100.00 |





Figure 3.6 Connected load in sharing on Electrical appliance



3.6 Some Photograph of Electrical Equipment's: -





CHAPTER- 4

ENERGY CONSERVATION MEASURES

4.1 Case Study

Replacement of conventional (tube light) 54 Watt by energy efficient 20 Watt LED tube light

| Sr. No. | Items | Parameters | Units |
|---------|---------------------------------------------------------|------------|------------|
| 1 | Total Power Consumption by T-12 conventional tube light | 54 | Watt |
| 2 | No. of T-12 | 429 | Nos. |
| 3 | Working Hrs./Day | 8 | Hrs./Day |
| 4 | Working Days/Year | 250 | Days/Year |
| 5 | Rated Power of Energy Efficient T-5 (LED) | 20 | W |
| 6 | Energy Saving Potential | 29,172 | kWh/Year |
| 7 | Load Factor | 0.8 | |
| 8 | Expected Annual Energy Saving | 23,337/- | kWh/Year |
| 9 | Overall, Per Unit Charges | 11.93 | Rs./kWh |
| 10 | Expected Money Saving | 27,8417/- | Rs./Year |
| 11 | Cost of T-5 | 200/- | Rs./ Pices |
| 12 | Investment on New Light Purchasing | 85,800/- | Rs. |
| 13 | Maintenance Investment@5% | 4,290/- | Rs. |
| 14 | Total Investment | 90,090/- | Rs. |
| 15 | Simple Pay Back Period | 4 | Month |



4.2 Case Study

Replacement of 60W conventional ceiling fan by 28W BLDC Energy efficient ceiling fan in institute: -

| Sr. No. | Item | Parameter | Unit |
|---------|---------------------------------------|------------|------------|
| 1 | Rated Power of Ceiling Fan | 60 | W |
| 2 | No. of Fan | 519 | Nos |
| 3 | Working Hrs./Day | 8 | Hrs./Day |
| 4 | Working Days/Year | 250 | Days/Year |
| 5 | Energy Efficient BLDC Fan Rated power | 28 | W |
| 6 | Energy Saving Potential | 33,216 | kWh/Year |
| 7 | Load Factor | 0.8 | |
| 8 | Expected Annual Energy Saving | 26,572.8 | kWh/Year |
| 9 | Per Unit Charges | 11.93/- | Rs/kWh |
| 10 | Expected Money Saving | 3,17,014/- | Rs./Year |
| 11 | Cost of New Ceiling Fan | 1,600/- | Rs./Pisces |
| 12 | Investment on New Fan Purchasing | 8,30,400/- | Rs. |
| 13 | Maintenance Investment@5% | 41,520/- | Rs. |
| 14 | Total Investment | 8,71,920/- | Rs. |
| 15 | Simple Pay Back Period | 2.8 | Year |

Total Calculated Monetary Saving Potential in Ceiling Fan = Rs 3,17,014/-

Note: - Energy saving depends on the operation hour per day and load factor of the systems.



4.3 Case Study

Installation 52.80 kWp grid connected solar roof top system

Solar unit (Energy) Generation calculation: -

| Theoretical capacity calculation of solar plant on Transformer Capacity | | | |
|--------------------------------------------------------------------------------|------------------------------------------------------------------------------------|---------|----------|
| 1 | Existing Transformer Capacity | 200 | KVA |
| 2 | Maximum theoretical limit as per Net Metering policy of electricity board | 33 | % |
| 3 | Maximum theoretical Potential limit of solar plant as per the transformer capacity | 66 | KVA |
| 4 | Power Factor of the Electrical System | 0.8 | |
| 5 | Theoretical solar plant capacity as per transformer Capacity | 52.80 | KWp |
| 6 | Expected Solar Unit generation @4 unit/day/KWp | 211.2 | kWh/Day |
| 7 | Expected Annual Solar Unit generation of the Solar Plant | 77,088 | KWh/Year |
| 8 | Annual Unit consumption of institute (Year 2021-22) | 15,2445 | kWh/Year |
| 9 | Normal energy consumption of the institute in Day Time | 64.5 | % |
| 10 | Normal energy consumption of the institute in Day Time | 98,327 | kWh/Year |

Analysis: As per the theoretical calculation of solar plant capacity based on transformer rated capacity is 52.80 kWp and expected annual unit generation of solar plant is 72270 units w.r.t annual energy consumption of the institute in day time is 982327 units. it is justified recommended the solar plant capacity 52.80kwp is accepted.

| Payback Period Calculation | | |
|---------------------------------------------------------|-------------|-----------|
| Total solar unit generation of the system (52.80 kwp) | 77,088 | kWh/ year |
| Overall Energy Charges per Unit as per electricity bill | 10 | |
| Expected revenue generation | 7,70,880/- | Rs./year |
| Expected cost of 1kw solar plant @50Rs.perwatt | 45,000/- | Rs./kwp |
| Expected total investment | 23,76,000/- | Rs. |
| Simple payback period of the project | 3.1 | year |



**Shivajirao Kadam Institute of Technology &
Management Near Ralamandal Sanctuary,
Tillore Khurd, Indore (M.P.)
Academic Year 2021-22**



**End of The Report
Thank you**